


# D192G Notification Appliance Circuit (NAC) Module

www.boschsecurity.com



**BOSCH**  
Invented for life



- ▶ Supervises 12 VDC or 24 VDC notification appliance circuits (NACs)
- ▶ Supervised signal silencing switch
- ▶ Notification appliance circuit rated at 3.0 A
- ▶ Multiple module configurations
- ▶ Mounts in panel enclosure

This module is used for wiring connections to remote signaling devices. You can connect up to twelve D192G modules to the same system on compatible control panels. Wiring is supervised for open, short, or grounded circuit faults.

The module powers notification appliances from the control panel power supply or from an Underwriters Laboratories, Inc. (UL 1481) Listed auxiliary 12 VDC or 24 VDC regulated/power-limited power supply for fire protective signaling units and commercial/residential burglar units. This feature allows the system to support more signaling devices on longer wire runs. It also allows the use of 12 V or 24 V notification appliances requiring the appropriate power supply.

## Functions

### Supervises 12 VDC or 24 VDC NACs

The D192G powers the notification devices from either the control panel's power supply or from a UL Listed Auxiliary 12 VDC or 24 VDC regulated power-limited power supply for use with Fire Protective Signaling Units and Commercial and Residential Burglar Units. The choice of power supply allows the use of 12 V or 24 V notification devices.

### Supervised Signal Silencing Switch

The D192G module has a toggle switch for silencing the notification devices while testing the alarm panel. When this toggle switch is in the Silence (Off) position, the module indicates a supervisory trouble condition to the control panel.

### Multiple Module Configurations

Several modules can be connected to the same zone or point on the control panel. If individual annunciation of a notification appliance circuit is desired, D192G modules can be connected to separate zones or points on-board or through the D8128D OctoPOPIT Eight-point Expander.

### Mounts in Panel Enclosure

The D192G mounts inside the control panel enclosure using existing mounting holes or with a D137 or D138 Mounting Bracket. Refer to the control panel's installation guide for more information on mounting.

## Certifications and approvals

Region	Certification
USA	UL AMCX: Central Station Alarm Units (UL1610, UL1635), APAW: Police Station Alarm Units (UL365, UL464), APOU: Proprietary Alarm Units (UL1076), NBSX: Household Burglar Alarm System Units (IL1023), UOJZ: Control Units, System (UL864, 9th edition)
	CSFM see our website
	FDNY-CoA #6174 UL 864 9th Edition
	NYC-MEA 12-92-E, Vol. 12 12-92-E, Vol. 12
	NYC-MEA 12-92-E, Vol. XV

## Installation/configuration notes

### Compatibility Information

Category	Product I
Control Panels	G-series <sup>1</sup>
	B-series <sup>2</sup>
	D9412 <sup>3</sup> , D7412 <sup>3</sup> , D7212 <sup>3*</sup>
	D9124 <sup>3</sup>
Detectors	For a list of compatible two wire detectors, refer to the <i>Approved Applications Compliance Guide</i> for the control panel being used.
Modules	D8128D OctoPOPIT Eight-point Expander
Mounting Brackets	D137 Mounting Bracket
	D138 Mounting Bracket, Right Angle

<sup>1</sup> G-series = D9412GV4, D7412GV4, D7212GV4\*, D9412GV3, D7412GV3, D7212GV3\*, D9412GV2, D7412GV2, D7212GV2\*, D9412G<sup>3</sup>, D7412G<sup>3</sup>, D7212G<sup>3\*</sup>

<sup>2</sup> B series = B5512 and B4512

<sup>3</sup> These products are legacy products and have been investigated for compatibility only to UL864 8th edition

\* The D7212 models are not listed for commercial fire applications

### Notification Appliances

Notification appliances used with the D192G Module must:

- Be polarized (DC) equipment
- Match the voltage rating of the alarm power supply
- Not exceed the current rating of the alarm power supply
- Not exceed 3.0 A in combined device current for each D192G Module

### Wiring

Use a Class B, Style W, two-wire circuit and wire according to the instructions supplied with the module. No more than twelve D192G modules can be used per system. For UL applications, a listed (UTRZ) regulated power supply can be used to power notification devices through the D192G module.

To comply with NFPA Standards:

- The control panel and power supply must be supervised or installed in the same room not more than 20 ft (6 m) from the module
- Wiring between the control panel and the power supply must be in conduit
- Power supply fault conditions must be supervised by a UL Listed relay

### Parts included

Quant.	Component
1	NAC module
1	Hardware pack
1	Literature pack

### Technical specifications

#### Electrical

##### External Power In

Current:	3.0 A maximum
Voltage:	12 VDC or 24 VDC nominal

##### Aux Power In

Current:	100 mA maximum
Voltage:	12 VDC nominal

##### Supervisory Zone Control

Current:	5 mA maximum
----------	--------------

#### Mechanical

Dimensions:	5 in. x 3 in. x 0.75 in. (13 cm x 8 cm x 2 cm)
-------------	--

### Ordering information

#### D192G Notification Appliance Circuit (NAC) Module

The D192G Notification Appliance Circuit (NAC) module is used for wiring connections to remote signaling devices. The wiring is supervised for open, short, or grounded circuit faults. Either 12 VDC or 24 VDC notification devices can be used depending on the choice of power supply.

Order number **D192G**

**Represented by:**

**Americas:**

Bosch Security Systems, Inc.  
130 Perinton Parkway  
Fairport, New York, 14450, USA  
Phone: +1 800 289 0096  
Fax: +1 585 223 9180  
security.sales@us.bosch.com  
www.boschsecurity.us

**Europe, Middle East, Africa:**

Bosch Security Systems B.V.  
P.O. Box 80002  
5617 BA Eindhoven, The Netherlands  
Phone: + 31 40 2577 284  
Fax: +31 40 2577 330  
emea.securitysystems@bosch.com  
www.boschsecurity.com

**Asia-Pacific:**

Robert Bosch (SEA) Pte Ltd, Security  
Systems  
11 Bishan Street 21  
Singapore 573943  
Phone: +65 6571 2808  
Fax: +65 6571 2699  
apr.securitysystems@bosch.com  
www.boschsecurity.asia

**China:**

Bosch (Shanghai) Security Systems Ltd.  
201 Building, No. 333 Fuquan Road  
North IBP  
Changning District, Shanghai  
200335 China  
Phone +86 21 22181111  
Fax: +86 21 22182398  
www.boschsecurity.com.cn

**America Latina:**

Robert Bosch Ltda Security Systems Division  
Via Anhanguera, Km 98  
CEP 13065-900  
Campinas, Sao Paulo, Brazil  
Phone: +55 19 2103 2860  
Fax: +55 19 2103 2862  
latam.boschsecurity@bosch.com  
www.boschsecurity.com