

ATEX Rated Explosion Proof Conduit Union INSTALLATION SHEET



FITTINGS FOR USE IN ZONE CLASSIFIED HAZARDOUS LOCATIONS

CML 16ATEX1325X

CE 2813 II 2 G D

Ex db IIC Gb or* Ex db IIB Gb

Ex tb IIIC Db IP65 / IP66*

Operating Temperature Range: -50°C to + 100°C or -50°C to + 400°C*

* For Ex d Gas Group, IP Ratings, and Service Temperature Range (by Cat. No.), See Table 1 below **IECEX QPS 16.0012X**

Ex db IIC Gb or* Ex db IIB Gb Ex tb IIIC Db IP65 / IP66* T_{amb}= -50 °C to +100 °C

1. General Safety Information:

 T_{amb} = -50 °C to +100 °C

CAUTION: Before installing, make sure you are compliant with area classifications, failure to do so may result in bodily injury, death and property damage. Do not attempt installation until you are familiar with the following procedures. All installation must comply with the applicable Electrical Code.

Make sure that the circuit is De-energized before starting installation or maintenance.

Verify that the installation is grounded. Failure to ground will create electrical shock hazards, which can cause serious injury and or death.

<u>Important</u>: Please read these instructions carefully before installing or maintaining this equipment. Good electrical practices should be followed at all times and this data should be used as a guide only

Technical information, advice and recommendations contained in these documents is based upon information that Killark believes to be reliable. All the information and advice contained in these documents is intended for use only by persons having been trained and possessing the requisite skill and know-how and to be used by such persons only at their own discretion and risk. The nature of these instructions is informative only and does not cover all of the details, variations or combinations in which this equipment may be used, its storage, delivery, installation, check out, safe operation and maintenance. Since conditions of use of the product are outside of the care, custody and control of Killark, the purchaser should determine the suitability of the product for his intended use, and assumes all risk and liability whatsoever in connection therewith.

2. Application Information

UNIONS: Series ATEX-EPL-UN-ALU-90-MF are the Larson Electronics Aluminum series are used to join two opposing pieces of conduit or attach secure conduit pieces to junction boxes, devices or other fittings.

Larson Electronics, LLC Phone: 877-348-9680 Fax: (903) 498-3364 www.larsonelectronics.com 1 of 1



3. Installation Instructions

CAUTION: THREAD TYPE and SIZE are marked on the fitting / adaptor and must be respected.

ONLY ONE threaded fitting / adaptor is permitted per cable entry. Never use reducers when installing fittings into an enclosure.

BLANKING ELEMENTS shall not be used with fittings / adaptors.

If the enclosure is already in operation, it must be DISCONNECTED from the supplying circuit before beginning installation.

Step 1

Ensure fitting thread type and size are compatible with enclosure thread. Where IPx5 or IPx6 ingress protection is required, the use of a suitable non-setting thread sealant on all flamepath joints is required.

Step 2

Tighten nipple into the enclosure/equipment with a wrench located on the center of the nipple. The nipple should be hand tight plus one wrench turn per ANSI/ASME B1.20.1-1983.

The number of threads engaged must be a minimum of 5.

Notes:

- 1. Nipples shall not be used for the direct inter-connection of enclosures.
- 2. Only one nipple is to be used with any singe cable entry on the associated equipment.
- 3. Recommended minimum bolt torque is 16.3 Nm (12 lb-ft.).

4. Conditions of Safe Use

- 1. With the exception of the IP66-rated Capped Elbows, the standard operating temperature range for all listed fittings is from -50 °C to +400 °C. For the IP66-rated Capped Elbow (with gasketed, threaded cover-to-housing joint), the standard operating temperature range is from -50 °C to +100 °C.
- 2. A seal is not required between the fitting and a flameproof enclosure, provided::
 - 1) volume up to 160 litters, and simple internal geometry, or
 - 2) reference pressure up to 234 psi (for IIC), 196 (for IIB)

whichever of these two conditions is reached first.

- ** A seal is required within 50 mm of the fitting/adaptor free end.
- 3. In application with larger flameproof enclosures (equal to and above 2/3 of the volume of 160 litres), or those with high reference pressure value (equal to and above 2/3 of the maximum reference pressure values stated above), a further investigation of the necessity of the use of seal may be required if:
- for group IIB the enclosure has been populated on such a way that one or more cross-section areas do not remain minimum 20% free.
- for group IIC the enclosure has been populated on such a way that one or more cross-section areas do not remain minimum 40% free.

Larson Electronics, LLC Phone: 877-348-9680 Fax: (903) 498-3364 www.larsonelectronics.com 1 of 2



5. Certification Information CML 16ATEX1325X / IECEx QPS16.0012X

Ex db IIB Gb Ex db IIB Gb Ex tb IIIC Db IP65 or Ex tb IIIC Db IP66

or

Ex db IIC Gb Ex db IIC Gb

Ex tb IIIC Db IP65 or Ex tb IIIC Db IP66

 T_{amb} = -50 °C to +100 °C

Standards Applied: IEC/EN 60079-0; IEC/EN 60079-1; IEC/EN 60079-31

See Certificates for Editions of Standards used.

Table 1 - ATEX / IECEX RATINGS by Cat. No.

illark ELBOWS and UNIONS - Hazloc and IP Ratings

March 23, 2020

Service Temp. Range = -50°C to +400°C (-50°C to +100°C for gasketed Y-Series); All fittings may be installed on enclosures with Volumes ≤ 160 Liters with no seal required at the enclosure.

Std. Elbows - Ex db	IIC Gb; Ex tb IIIC Db IP66	IP Rating	
FF-90-1-EX	FF-90-1M-EX	IP66	
FF-90-2-EX	FF-90-2M-EX	IP66	
FF-90-3-EX	FF-90-3M-EX	IP66	
FF-45-1-EX	FF-45-1M-EX	IP66	
FF-45-2-EX	FF-45-2M-EX	IP66	
FF-45-3-EX	FF-45-3M-EX	IP66	
FF-45-4-EX	FF-45-4M-EX	IP66	
FF-45-5-EX	FF-45-5M-EX	IP66	
FF-45-6-EX	FF-45-6M-EX	IP66	
FF-45-8-EX	FF-45-8M-EX	IP66	
MF-90-1-EX	MF-90-1M-EX	IP66	
MF-90-2-EX	MF-90-2M-EX	IP66	
MF-45-1-EX	MF-45-1M-EX	IP66	
MF-45-2-EX	MF-45-2M-EX	IP66	
MM-30-1-EX	MM-90-1M-EX	IP66	
MM-90-2-EX	MM-90-2M-EX	IP66	
BL-90-1-EX	BL-90-1M-EX	IP66	
BL-90-2-EX	BL-90-2M-EX	IP66	
BL-90-3-EX	BL-90-3M-EX	IP66	

IP Rating	Capped Elbows - Ex db IIC Gb; Ex tb IIIC Db IP66	
	Iron	Alum.
IP66*	Y-1M-EX	Y-1-EX
IP66*	Y-2M-EX	Y-2-EX
IP66*	Y-3M-EX	Y-3-EX
IP66*	Y-4M-EX	Y-4-EX
IP66*	Y-5M-EX	Y-5-EX

Y-Sorioz Cappod Elbaur aro ratod Ex tb and IP66 (ruitablo for a
Service Temperature range of -50°C to +100°C) when provided
with the Silican Caver Garket. When garket is not present, the Y-
Sories fittings are Flamoproof (Exdprotection) only.

	Swivel Elbows - Ex db IIB; Ex tb IIIC IP65		IP D-vi
	Alum.	Iron	Rating
1	GUFS-1-EX	GUFS-1M-EX	IP65
	GUFS-2-EX	GUFS-2M-EX	IP65
	GUMFS-1-EX	GUMFS-1M-EX	IP65
	GUMFS-2-EX	GUMFS-2M-EX	IP65

90" Plugged Elbows – Ex db IIC Gb; Ex tb IIIC Db 1P66		IP Rating
Alum.	Iron	
EYMF-1-EX		IP66
		IP66

Female to Female - Ex db IIC Gb; Ex tb IIIC Db IP65		IP Rating
Alum.	Iron	
GUF-1-EX	UNF1-EX	IP65
GUF-2-EX	UNF2-EX	IP65
GUF-3-EX	UNF3-EX	IP65
GUF-4-EX	UNF4-EX	IP65
GUF-5-EX	UNF5-EX	IP65
GUF-6-EX	UNF6-EX	IP65
GUF-7-EX	UNF7-EX	IP65
GUF-8-EX	UNF8-EX	IP65
GUF-9-EX	UNF9-EX	IP65
GUF-0-EX	UNF0-EX	IP65

Male to Female - Ex db IIC Gb; Ex tb IIIC Db IP65		IP Rating
Alum.	Iron	
GUM-1-EX	UNY1-EX	IP65
GUM-2-EX	UNY2-EX	IP65
GUM-3-EX	UNY3-EX	IP65
GUM-4-EX	UNY4-EX	IP65
GUM-5-EX	UNY5-EX	IP65
GUM-6-EX	UNY6-EX	IP65
GUM-7-EX	UNY7-EX	IP65
GUM-8-EX	UNY8-EX	IP65
GUM-9-EX	UNY9-EX	IP65
GUM-0-EX	UNY0-EX	IP65

Unions

90° Angle - Ex db IIC Gb; Ex tb IIIC Db IP65		IP D. ti
Alum.	Iron	Rating
GUML-1-EX	GUML-1M-EX	IP65
GUML-2-EX	GUML-2M-EX.	IP65

Male to Male - Ex db IIC Gb; Ex tb IIIC Db		IP Rating
Alum.	Iron	Rating
GUMM-1-EX		IP65
GUMM-2-EX		IP65
GUMM-3-EX		IP65

THESE INSTRUCTIONS MAY NOT COVER ALL DETAILS OR VARIATIONS OF THIS PRODUCT FOR YOUR EQUIPMENT OR INSTALLATION REQUIREMENTS. SHOULD FURTHER INFORMATION NOT COVERED BY THESE INSTRUCTIONS BE REQUIRED, PLEASE CONTACT LARSON ELECTRONICS BY EMAIL AT <u>SALES@LARSONELECTRONICS.COM</u> OR BY PHONE AT 1-877-348-9680 FOR FURTHER ASSISTANCE.

PLEASE VISIT LARSONELECTRONICS.COM FOR WARRANTY AND RETURN INFORMATION.

Larson Electronics, LLC Phone: 877-348-9680 Fax: (903) 498-3364 www.larsonelectronics.com 1 of 3